



HARGROUND™

High Compression Grounding Series CGCR

Catalog Number	Accommodates		② Cable to Reinforcing Steel		Installation Data	
	Run	Tap	Run	Tap	Die Index	No. of Crimps
CGCR2504	1/0 Str. (0.372) through 250 kcmil (0.575) 1/2" - 5/8" Rod	#4 Sol. (0.204) - #2 Str. (0.292)	#3 - #4 Reinforcing Steel	#2 Str. (0.292)	U997	1
CGCR2501/0		1/0 Str. (0.372) - 2/0 Str. (0.419)	#3 - #4 Reinforcing Steel	1/0 Str. (0.372) - 2/0 Str. (0.419)		1
CGCR2503/0 ①		3/0 Str. (0.470) - 250 kcmil (0.575)	#3 - #4 Reinforcing Steel	3/0 Str. (0.470) - 250 kcmil (0.575)		1
CGCR5004	250 kcmil (0.575) through 500 kcmil (0.813) 5/8" - 3/4" Rod	#4 Sol. (0.204) - #2 Str. (0.292)	#5 - #6 Reinforcing Steel	-----	U998	1
CGCR5001/0		1/0 Str. (0.372) - 2/0 Str. (0.419)	#5 - #6 Reinforcing Steel	1/0 Str. (0.372) - 2/0 Str. (0.419)		1
CGCR5003/0		3/0 Str. (0.470) - 250 kcmil (0.575)	#5 - #6 Reinforcing Steel	3/0 Str. (0.470) - 250 kcmil (0.575)		1

Notes:

- ① When using 3/0 in tap, minimum run conductor must be 2/0 Str.
- ② Clean rust and protective coatings from reinforcing steel prior to installation to provide proper ground connection. Precrimping is not required.
- When attaching connector to ground rod, ground rod must be embossed with appropriate precrimping die.

Ground Rod Dia.	Precrimping Dies
1/2"	U2CABT
5/8"	U2CABT
3/4"	U2CABT